

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 11:44 am

**PWS ID:** UTAH04007      **Name:** PRICE MUNICIPAL CORPORATION  
**Legal Contact:** PRICE MUNICIPAL CORPORATION      **Rating:** Approved  
GARY D SONNTAG      **Rating Date:** 06/22/1978  
**Address:** PO BOX 893      **Activity Status:** Active  
PRICE, UT 84501  
**Phone Number:** 435-637-5010  
**City Served (Area):**  
**County:** CARBON COUNTY  
**System Type:** Community      **Last Inv Update:** 07/18/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 06/23/2008      **Total Dsgn Cap:**  
**Population:** 8,010      **Surveyor:** DAVID ARIOTTI      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	SONNTAG, GARY D	PUBLIC WORKS	435-637-5010	435-636-6762	gary@priceutah.net

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Metered	1	327
Residential	Metered	0.75	2,851
			3,178 Total Svc Connections

### Storage

**Total Storage:** 13,000,000 G<sup>3</sup>      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	WOOD HILL 10 MG STORAGE TANK	Ground	10,000,000 MG <sup>3</sup>	Concrete		A	NO
ST002	SAGE WOOD 3 MG STORAGE TANK	Reservoir	3,000,000 GAL	Steel		A	NO

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	COLTON SPRINGS CHLORINATOR		I	
TP004	PRICE RIVER WTP		A	

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	LOWER COLTON SPRINGS	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	UPPER COLTON SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS003	UTAH POWER AND LIGHT S	Inactive	WL	12	900 GPM	1,200 GPM	Yes	GW	Emergency	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.

## Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS004	PRICE RIVER INTAKE	Active	IN				Yes	SW	Permanent	1/1 to 12/31	
WS005	UTAH POWER AND LIGHT N	Inactive	WL	14	1200 GPM	2,500 GPM	Yes	GW	Emergency	1/1 to 12/31	
WS006	UTAH04020 PRICE RIVER V	Active	CC				No	SW	Permanent	1/1 to 12/31	
WS007	EMMA PARK WELL NO. 1	P	WL				No	GW	Permanent	1/1 to 12/31	
WS008	EMMA PARK WELL NO. 2	P	WL				No	GW			

*\*Reports measured flow for wells, approved design capacity for all other sources.*